

# KERALA STATE NIRMITHI KENDRA



## NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695 013  
PHONE No. : 2362229

No. **16989**

No: T5/922/2021-22/RNK-TVPM

Date: **27.07.2023**

Ref: -- as request letter dtd 27.07.2023

Testing of: 5 nos of concrete cube supplied - for testing compressive strength

Cash Remittance: Amount **₹ 2360/-** Invoice No. **3867** Date **27.07.2023**

To **Mo. Anoop  
Kannanmoola**

TEST RESULTS				
Identification of the Cube	Mix	Date of Casting	Maximum Load taken (kN)	Compressive Strength (N/mm <sup>2</sup> )
1	M20	13.07.2023	450	20.00
2	M20	13.07.2023	440	19.56
3	M20	13.07.2023	430	19.11
4	M20	13.07.2023	440	19.56
5	M20	13.07.2023	430	19.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED

Office Seal

*Suresh Babu*  
B

*Thiru Anoop*  
For DIRECTOR

# KERALA STATE NIRMITHI KENDRA



## NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695 013  
PHONE No. : 2362229

No. **16990**

No: T5/922/2021-22/RNK-TVPM

Date: 21.07.2023

Ref: Your request letter

Testing of: 3 nos of concrete cube supplied for testing compressive strength

Project: J-KL-KJML-ENG-9002, Manaveli jn

Cash Remittance: Amount ₹116/- Invoice No. 3871 Dated 21.07.2023

To M/s Kasakkattil Projects & Infrastructure Pvt Ltd.

### TEST RESULTS

Identification of the cube	Mix	Date of Casting	Maximum load taken (KN)	Compressive Strength (N/mm <sup>2</sup> )
KJML-9002	M20	21.07.2023	460	20.44
KJML-9002	M20	21.07.2023	450	20.00
KJML-9002	M20	21.07.2023	440	19.56

Test conducted by:

Signature:

Verified by:

Shana S, Overseer

Signature:

Shana

COUNTER SIGNED AND ISSUED



For DIRECTOR



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695 013  
PHONE No. : 2362229

No. 6991

No: T5/922/2021-22/RNK-TVPM

Date: 27.07.2023

Ref: Gas request letter

Testing of: 3 nos of concrete cube supplied for testing compressive strength

Project: J-KL-KJML-ENG-9002, Manaveli Jo

Cash Remittance: Amount ₹ 1416/- Invoice No. 3871 Date 27-07-2023

To M/s Karakkattil Projects & Infrastructure Pvt Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of Casting	Maximum load taken (kN)	Compressive Strength (N/mm <sup>2</sup> )
KJML-9002	M20	20.07.2023	400	17.78
KJML-9002	M20	20.07.2023	380	16.89
KJML-9002	M20	20.07.2023	360	16.00

Test conducted by:

Signature:

Verified by:

Shana S, Overseer

Signature:

Shana

COUNTER SIGNED AND ISSUED



For DIRECTOR

# KERALA STATE NIRMITHI KENDRA

## NIRMITHI TESTING LABORATORY



CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695 013  
PHONE No. : 2362229

No. 16992

No: T5/922/2021-22/RNK-TVPM

Date: 21.07.2023

Ref: Your request letter No. 10CL/TDO/RO. Hassan dtd 12.07.2023

Testing of: 3 nos of concrete cube supplied - Bs - testing compressive strength

Cash Remittance: Amount ₹ 1416/- Invoice No. 3812 Date 21.07.2023

To M/S INDIAN OIL CORPORATION LIMITED

### TEST RESULTS

Identification of the cube	Mix	Date of Casting	Maximum load taken (kN)	Compressive Strength (N/mm <sup>2</sup> )
1	M <sub>25</sub>	16.06.2023	680	30.22
2	M <sub>25</sub>	16.06.2023	700	31.11
3	M <sub>25</sub>	16.06.2023	720	32.00

Test conducted by:

Signature:

Verified by:

Shana S, Overseer

Signature:

COUNTER SIGNED AND ISSUED



For DIRECTOR

# KERALA STATE NIRMITHI KENDRA

## NIRMITHI TESTING LABORATORY



CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695 013  
PHONE No. : 2362229

No. **16993**

No: T5/922/2021-22/RNK-TVPM

Date: 27.07.2023

Ref: Your request letter dtd 27.07.2023

Testing of: 3 nos of concrete cube supplied for testing  
compressive strength

Project: Piling at Urbanscape Properties Solitaire site at  
Vattiyookavu

Cash Remittance: Amount ₹1416/- Invoice No. 3868 Date 27.07.2023

To

Mr. Chinnan. P  
Project Engineer

### TEST RESULTS

Identification of the Cube	Mix	Date of Casting	Maximum load taken (KN)	Compressive Strength (N/mm <sup>2</sup> )
1	M <sub>30</sub>	28.06.2023	750	33.33
2	M <sub>30</sub>	28.06.2023	740	32.89
3	M <sub>30</sub>	28.06.2023	770	34.22

Test conducted by:

Signature:

Verified by:

Shana S, Overseer

Signature:

Shana

COUNTER SIGNED AND ISSUED

Office Seal



For DIRECTOR



# KERALA STATE NIRMITHI KENDRA

## NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695 013  
PHONE No. : 2362229

No. **16994**

No: T5/922/2021-22/RNK-TVPM

Date: 21.07.2023

Ref: Your request letter dttd 21.07.2023

Testing of: 3 nos of concrete cube supplied - for testing compressive strength

Project: Ramachandran Commercial Project at Thiruvananthapuram

Cash Remittance: Amount ₹1416/- Invoice No. 3870 Date 21.07.2023

To M/s Prime Bricks

TEST RESULTS				
Identification of the Cube	Mix	Date of Casting	Maximum load taken (KN)	Compressive Strength (N/mm <sup>2</sup> )
TF-RS-2	M <sub>30</sub>	20.07.2023	700	31.11
TF-RS2	M <sub>30</sub>	20.07.2023	770	34.22
TF-RS2	M <sub>30</sub>	20.07.2023	760	33.78

Test conducted by:

Signature:

Verified by:

*Shana S, Overseer*

Signature:

*Shana*

COUNTER SIGNED AND ISSUED



*[Signature]*  
For DIRECTOR

# KERALA STATE NIRMITHI KENDRA



## NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695 013  
PHONE No. : 2362229

No. **16995**

No: T5/922/2021-22/RNK-TVPM

Date: 27.07.2023

Ref: Your request letter No 1001/100/RO - Hassan dtd 12.07.2023

Testing of: 3 nos of concrete cube supplied - for testing compressive strength

Project: Casting of top slab of tank no:2 of retail Outlet, M/s Hassan Brothers, Kappalattom, Thiruvananthapuram

Cash Remittance: Amount ₹1416/- Invoice No. 3812 Date 27.07.2023

To M/s Indian Oil Corporation Limited

TEST RESULTS				
Identification of the Cube	Mix	Date of Casting	Maximum Load taken (KN)	Compressive Strength (N/mm <sup>2</sup> )
1	M <sub>25</sub>	15.06.2023	680	30.22
2	M <sub>25</sub>	15.06.2023	700	31.11
3	M <sub>25</sub>	15.06.2023	690	30.67

Test conducted by:

Signature:

Verified by:

Shana S, Overseer

Signature:



COUNTER SIGNED AND ISSUED

For DIRECTOR