



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17018

Date:05.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd.05.08.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

Project Name:Reliance Jio Infocomm Limited

Site:Dhanuvachapuram Site ID : KCWG-ENB-9007

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3919	Invoice Date: 05.08.2023

To

M/S Sree Shastha Constructions

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	29.07.2023	540	24
2	M ₂₀	29.07.2023	580	25.78
3	M ₂₀	29.07.2023	460	20.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17019

Date:05.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter No.QA/SFS/008/52 dtd.05.08.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

Project Name:SFS AMBER Blue block 6th floor column

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3920	Invoice Date: 05.08.2023

To

M/S Skyline Foundation & Structure(P)Ltd

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₄₅	29.07.2023	1020	45.33
2	M ₄₅	29.07.2023	1030	45.78
3	M ₄₅	29.07.2023	760	33.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17020

Date:05.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd.05.08.2023

Testing of: 2 nos of concrete cube supplied for testing compressive strength.

Project Name:Petrol pumb-Killi - Canopy Foundation

CASH REMITTANCE DETAILS		
Amount: 944/-	Invoice No. 3925	Invoice Date: 05.08.2023

To

M/S EPSILON

Reliance BP mobility Ltd,

Kottapuram,Kollode PO,

Kattakada,TVM

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₅	30.07.2023	590	26.22
2	M ₂₅	30.07.2023	640	28.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17022

Date:05.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd 05.08.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

Project Name: Ramachandran Commercial Project at Thirumala

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3921	Invoice Date: 05.08.2023

To

M/S Prime Bricks

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
F-C	M ₄₀	29.07.2023	880	39.11
F-C	M ₄₀	29.07.2023	860	38.22
F-C	M ₄₀	29.07.2023	730	32.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17023

Date:05.08.2023

Ref:- Your request letter dtd.26.07.2023

Testing of: 3 nos of concrete cube supplied for testing 14th day compressive strength.

Project Name:KEPCO,Kudappanakunnu.

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3869	Invoice Date: 27.07.2023

To

Regional Engineer
Kerala State Nirmithi Kendra,
Regional office,Vattiyoorkavu.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	21.07.2023	600	26.67
2	M ₂₀	21.07.2024	600	26.67
3	M ₂₀	21.07.2025	590	26.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer