



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17026

Date:09.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

Site ID : KLML 9041

CASH REMITTANCE DETAILS

Amount: 1416/-	Invoice No. 3936	Invoice Date: 09.08.2023
----------------	------------------	--------------------------

To

M/S Reliance Jio

Geethanjali Building

Opp Ganapathy kovil road,Vazhuthakadu

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	1.08.2023	450	20
2	M ₂₀	1.08.2023	450	20.22
3	M ₂₀	1.08.2023	440	19.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17027

Date:09.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter No.AE/LSGD/PGD0/QH -02.2023-24 dtd 08.08.23

Testing of: Concrete cube supplied for testing compressive strength.

Project Name:Pile Cap phase-1

CASH REMITTANCE DETAILS

Amount: 472/-	Invoice No. 3938	Invoice Date: 09.08.2023
---------------	------------------	--------------------------

To

Mr.Jose

Architect

Thakaraparambu

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	12.07.2023	600	26.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17028

Date:09.08.2023

Ref:- Your request letter dtd.09.08.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3944	Invoice Date: 09.08.2023

To

M/S Cordial Homes Private Limited

Cordial Paradise,Poojapura.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	12.07.2023	640	28.44
2	M ₂₅	12.07.2023	630	28
3	M ₂₅	12.07.2023	600	26.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17029

Date:09.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter No.QA/SF S/008/53 dtd. 09.08.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

Site : Third floor Part 2 Slab.

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 6941	Invoice Date: 09.08.2023

To

M/S Skyline Foundation & Structures

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₃₀	11.07.2023	910	40.44
II	M ₃₀	11.07.2023	1120	49.78
III	M ₃₀	11.07.2023	980	43.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17030

Date:09.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd.07.08.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

Project Name:Ambedkar Settlement Kadambravaram at Attingal

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3928	Invoice Date: 07.08.2023

To

The Regional Engineer

Kerala State Nirmithi Kendra

Regional Office, Vattiyorkavu

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	02.08.2023	450	20
2	M ₂₀	02.08.2023	450	20
3	M ₂₀	02.08.2023	440	19.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17031

Date:09.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter No.SCTL/PRJ/1291/2020/AN(c)/7499 dtd.27.07.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

Project Name:Development of Multi Level Car Parking at Palayam A Block

File Id -26,16,105,97

CASH REMITTANCE DETAILS

Amount: 1416/-	Invoice No. 3942	Invoice Date: 09.08.2023
----------------	------------------	--------------------------

To

The Senior Manager (PMM)

Smart City Thiruvananthapuram Ltd(SCTL)

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	30.06.2023	980	43.56
2	M ₃₀	30.06.2023	980	43.56
3	M ₃₀	30.06.2023	1070	47.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17032

Date:09.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter No.SCTL/PRJ/1291/2020/Am(c)/7499 dtd.27.07.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.
Project Name:Development of Multi Level Car Parking at Palayam A Block
Pile Id -5,6

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3942	Invoice Date: 09.08.2023

To

The Senior Manager (PMM)

Smart City Thiruvananthapuram Ltd(SCTL)

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	20.06.2023	910	40.44
2	M ₃₀	20.06.2023	740	32.89
3	M ₃₀	20.06.2023	920	40.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer

0

