



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17033

Date : 10.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd 07.08.2023

Testing of: 3nos of concrete cube supplied for testing compressive strength.

Project : Ambedkar settlement Kadambavaram at Attingal.

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3928	Invoice Date: 07.08.2023

To

The Regional Engineer
Kerala State Nirmithi Kendra
Regional Office, Vattiyookavu

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	27.07.2023	370	16.44
2	M ₂₀	27.07.2023	370	16.44
3	M ₂₀	27.07.2023	360	16

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17034

Date : 10.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter No.QA/SFS/008/54 dtd 10.08.2023

Testing of: 3nos of concrete cube supplied for testing compressive strength.

Project : SFS AMBER BLUE BLOCK 5th floor slab and beam.

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3946	Invoice Date: 10.08.2023

To

M/S Skyline Foundation & Structures (P) Ltd

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	13.07.2023	1060	47.11
2	M ₃₀	13.07.2023	1180	52.44
3	M ₃₀	13.07.2023	1010	44.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17035

Date : 10.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter No.QA/SFS/008/55 dtd 10.08.2023

Testing of: 3nos of concrete cube supplied for testing compressive strength.

Project : SFS AMBER -Trial mix

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3946	Invoice Date: 10.08.2023

To

M/S Skyline Foundation & Structures (P) Ltd

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₄₀	02.08.2023	830	36.89
2	M ₄₀	02.08.2023	840	37.33
3	M ₄₀	02.08.2023	840	37.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17037

Date : 10.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter

Testing of: 3nos of concrete cube supplied for testing compressive strength.

Project : I-KL-KLLM-ENB-0253,KLM-KACHERY Jn.

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3947	Invoice Date: 10.08.2023

To

M/S Karakkattil Projects & Infrastructures Pvt Ltd

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
KLLM-0253	M ₂₀	13.07.2023	710	31.56
KLLM-0253	M ₂₀	13.07.2023	620	27.56
KLLM-0253	M ₂₀	13.07.2023	730	32.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer