

NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17055

No. T5/922/2021-22/RNK-TVPM

Date:18.08.2023

Ref:- Your request letter No.CNP/08-2023 dtd.18.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compresive strength.

Project:-

CYBER DOME PROJECT - Chanakya Nirman.

Amount:1416/- Invoice No. 3992 Invoice Date: 18.08.2023

To M/S Chankya Nirman Private Limited.

TEST RESULTS					
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)	
S_1	M_{30}	16.07.2023	730	32.44	
S ₂	M_{30}	16.07.2023	650	28.89	
S_3	M ₃₀	16.07.2023	700	31.11	

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

THE THE PARTY OF T



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17056

9thing James

No. T5/922/2021-22/RNK-TVPM

Date:18.08.2023

Ref:- Your request letter No.CNP/08-2023 dtd.18.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compresive strength.

Project:-

CYBER DOME PROJECT - Chanakya Nirman.

Amount:1416/- Invoice No. 3992 Invoice Date: 18.08.2023

To M/S Chankya Nirman Private Limited.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
GF1	M_{30}	31.07.2023	680	30.22
GF2	M_{30}	31.07.2023	690	30.67
GF3	M_{30}	31.07.2023	650	28.89

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:17057

Ham (min)

No. T5/922/2021-22/RNK-TVPM Date: 18.08.2023

Ref:- Your request letter dtd.18.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compresive strength.

Project:-

Hotel Lemon Tree.

Amount:1416/- Invoice No. 3991 Invoice Date: 18.08.2023

To M/S AR Vista Pvt. Ltd.

TEST RESULTS					
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)	
1	M_{30}	20.07.2023	960	42.67	
2	M_{30}	20.07.2023	1280	56.89	
3	M_{30}	20.07.2023	1300	57.78	

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

KENANAMIH KENDES BELLEVILLE



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17058

No. T5/922/2021-22/RNK-TVPM

Date:18.08.2023

Ref:- Your request letter dtd.18.08.2023.

Testing of: 3 no's of Interlock Paver Block (10mm thick) supplied for testing compresive strength.

Amount:1416/-	Invoice No. 3977	Invoice Date: 16.08.2023

To M/S JAS POWER BLOCK INTERLOCK & TILE HOLLOW BRICKS

TEST RESULTS					
Identification of the block	Area of the Block(mms)	Maximum load taken (KN)	Correction Factor	Corrected Compressive strength (N/mm2)	
I	30669	980	1.18	37.70	
II	30669	960	1.18	36.93	
III	30669	920	1.18	35.40	

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

THE REALITIME OF THE PROPERTY OF THE PROPERTY

Regional Engineer

Itam James

Office Seal



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:17059

No. T5/922/2021-22/RNK-TVPM

Date:18.08.2023

Ref:- Your request letter dtd.08.08.2023.

Testing of: 6 no's of Interlock Paver Block supplied for testing compresive strength (80mmthick).

Amount:2832/-	Invoice No. 3982	Invoice Date: 08.08.2023

Padmaja Consultant & Contract.

Indian

Oil Corporation Ltd. Ponganadu.

	TEST RESULTS				
Identification of the block	Area of the Block(mms)	Maximum load taken (KN)	Correction Factor	Corrected Compressive strength (N/mm2)	
1	30669	1280	1.18	49.25	
2	30669	1150	1.18	44.24	
3	30669	1480	1.18	56.95	
4	30669	1260	1.18	48.47	
5	30669	1190	1.18	45.78	
6	30669	1210	1.18	46.55	

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

WIN KENDER

Ithin common f



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:170560

No. T5/922/2021-22/RNK-TVPM

Date:18.08.2023

 $Ref:-\ Your\ request\ letter\ No.SCTL/PRJ/210/2019/PMM/7595.\ dtd.08.08.202$

Testing of: 4 no's of Interlock Paver Block supplied for testing compresive strength (100mmthick). Project:- Development of Smart Roads and Underground ducting including utility shifting of water supply and power lines in ABD area under smart city mission.

Amount:1888/-	Invoice No. 3988	Invoice Date: 17.08.2023

M/s Smart City Thiruvananthapuram Limited.

TEST RESULTS				
Identification of the block	Area of the Block(mms)	Maximum load taken (KN)	Correction Factor	Corrected Compressive strength (N/mm2)
I	30669	1430	1.18	55.02
II	30669	1230	1.18	47.33
III	30669	1050	1.18	40.40
IV	30669	1280	1.18	49.25

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED



9thing common p



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:170561

Date:18.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd.08.08.2023.

Testing of: 6 no's of 6" solid concrete blocks supplied for testing compresive strength.

Amount:2832/-	Invoice No. 3993	Invoice Date: 17.08.2023

M/s The Ramco Cements Limited.

TEST RESULTS					
Identification of the block	Size of the Block(mms)	Mximum Load Taken (KN)	Compressive strength (N/mm2)		
R	300X150X200	80	1.78		
R	300X150X200	88	1.96		
R	300X150X200	82	1.82		
D	300X150X200	160	3.56		
D	300X150X200	168	3.73		
D	300X150X200	148	3.29		

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

Office Seal

Regional Engineer

This chair



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:17062

No. T5/922/2021-22/RNK-TVPM

Date: 18.08.2023

Ref:- Your request letter dtd.18.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compresive strength.

Project:-

Third Floor Part 3 Slab.

Amount:1416/- Invoice No. 3995 Invoice Date: 18.08.2023

To M/s Cordial Homes Private Litmited.

Cordial

Layam.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
Cube no.3	M_{25}	21.07.2023	690	30.67
Cube no.4	M_{25}	21.07.2023	730	32.44
Cube no.5	M ₂₅	21.07.2023	690	30.67

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

SHOWN HEROPA POR BOOK OF THE PROPERTY OF THE P

Regional Engineer

9thing comment

Office Seal