NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17042 Da 14.08.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compresive strength.

Amount:1416/-	Invoice No. 3963	Invoice Date: 14.08.2023

To M/Scordial Homes Private Limited Cordial

Paradise Poojapura.

Г

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
SF II	M ₂₅	17.07.2023	660	29.33
SF II	M ₂₅	17.07.2023	680	30.22
SF II	M ₂₅	17.07.2023	820	36.44

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Han Charm

Office Seal

Regional Engineer



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17043 Date:14.08.2023

Ref:- Your request letter No.QA/SFS/008/56 Dtd.14.08.2023. Testing of: 3 no's of concrete cube supplied for testing compresive strength. SFS AMBER Green Block.

Project:

Amount:1416/-	Invoice No. 3965	Invoice Date: 14.08.2023

To M/Sskyline Foundation and Structures(P) Ltd

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
SF II	M ₄₅	15.07.2023	1230	54.67
SF II	M ₄₅	15.07.2023	1100	48.89
SF II	M ₄₅	15.07.2023	1100	48.89

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Hann Caron

Regional Engineer

Office Seal



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17044 Date:14.08.2023

Ref:- Your request letter dtd.14.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compresive strength. Project:Ramachandran Commercial Project at Thirumala.

A	
Amount:1416/- Invoice No. 3966 Invoice Date: 14.08.2023	

To M/S Prime Bricks

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
F - C	M ₄₀	29.07.2023	850	37.78
F - C	M_{40}	29.07.2023	950	42.22
F - C	M ₄₀	29.07.2023	890	39.56

Test conducted by: Verified by:

Signature: Signature:

COUNTER SIGNED AND ISSUED



Alen Caron

Regional Engineer

Office Seal



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17045 Da 14.08.2023

Ref:- Your request letter No.SJ/ENKL/C.T/07/2023 dtd.13.08.2023. Testing of: 3 no's of concrete cube supplied for testing compresive strength. Commercial Building Site at Enchakal.

Site:-

Amount:1416/-	Invoice No. 3967	Invoice Date: 14.08.2023

To M/S SJU HOMES AND DEVELOPERS PRIVATE LIMITED.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
Ι	M ₂₅	06.08.2023	400	17.78
II	M ₂₅	06.08.2023	380	16.89
III	M ₂₅	06.08.2023	380	16.89

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Harry Caron

Regional Engineer