



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
REGIONAL OFFICE  
KODUMBU, PALAKKAD  
PHONE No. 04912571492

No. Tech/108/13/RNK.P

Date: 5/7/2023

Ref:- 3nos of concrete cubes supplied for testing compressive strength  
on 7th day-main slab

Testing of: Renovation of college canteen construction cum co-operative store and post  
office building at govt arts and science college pathiripala palakkad

## CASH REMITTANCE DETAILS

Amount ₹	1416.00	Invoice No. 2432
----------	---------	------------------

To Mr.Abdul Rassak V A

Velliyath house, kuzhivellipady, edathala(p.o), aluva


## TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
M20 (26/06/2023)	M20	26/06/2023	260	11.55
"	"	"	400	17.77
"	"	"	380	16.88

Test conducted by: Jyothish.ks

Signature: 

Verified by: Santhandasan

Signature: 

## COUNTER SIGNED AND ISSUED



Office Seal



GIRISH. M.  
Regional Engineer  
Kerala State Nirmithi Kendra  
Regional Centre, Palakkad