

KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

Manakala Adoor

PHONE No. 8111882860

No. TS/187/2022/RNK/Adoor

Date: 10.08.2023

Ref:- Letter No. Nil dated 10.08.2023

Testing of: 02 Nos concrete cubes of M20 grade for after 28th day compressive strength for the construction of Commercial Building Project at Anandapalli from Fr. Kurian, Plankayil.

CASH REMITTANCE DETAILS				
Amount:- ₹ 944.00		Invoice No. T-ADR/2308/2		

To

Fr. Kurian Plankayil,

Ananthapalli, Adoor.

TEST RESULTS					
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)	
P1	M20	.13-07-2023	530	23.56	
P2	M20	.13-07-2023	580	25.78	

Test conducted by: Anjana, Site Engineer

Verified by: Sheeja S

COUNTER SIGNED AND ISSUED

Office Seal

Regional Engineer Kerala State Nirmithi Kendra Manakala, Adoor