



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17103

No. T5/922/2021-22/RNK-TVPM

Date: 02.09.2023

Ref:- Your request letter No.QA/SFS/008/68 dtd.01.09.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: SFS AMBER Green Block .

Amount:1416/-	Invoice No. 4059	Invoice Date: 01.09.2023
---------------	------------------	--------------------------

To M/s Skyline foundation and Srtuctures (P)Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₃₀	23.08.2023	650	28.89
II	M ₃₀	23.08.2023	790	35.11
III	M ₃₀	23.08.2023	800	35.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17104

No. T5/922/2021-22/RNK-TVPM

Date: 02.09.2023

Ref:- Your request letter dtd.02.09.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Forth floor part 2 slab .

Amount:1416/-	Invoice No. 4061	Invoice Date: 02.09.2023
---------------	------------------	--------------------------

To M/s Cordial Homes (P) LTD.

Cordial Layam

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	05.08.2023	550	24.44
4	M ₂₅	05.08.2023	600	26.67
5	M ₂₅	05.08.2023	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer