

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17118 Date:08.09.2023

Ref:- Your request letter dtd:25.08.2023

Testing of : 3 no's of concrete blocks(8",6",4") supplied for testing water absorption. Project: Asset Sovereign

Amount:2832/-	Invoice No. 4050	Invoice Date: 25.08.2023		

To M/s G.S.Builders & Contractors Pvt.Ltd.

TEST RESULTS					
Identification of the BlockSize of the Block(mms)		Maximum load taken (KN)	Compressive strength (N/mm2)		
8"SCB	400 X 200 X 200	590	7.38		
8"SCB	400 X 200 X 200	522	6.53		
6"SCB	400 X 150 X 200	488	8.70		
6"SCB	6"SCB 400 X150 X 200 4"SCB 400 X 100 X 200 4"SCB 400 X 100 X 200		5.47		
4"SCB			4.50		
4"SCB			5.50		

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Ham Charmen

Regional Engineer



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

No.17119 Date:08.09.2023

Ref:- Your request letter dtd.04.09.2023.

Testing of: 3 no's of Interlock Paver Block (80mm thick) supplied for testing compresive strength(4" Interlock).

Amount:1416/-	Invoice No. 4067	Invoice Date: 04.09.2023

To M/S JAS POWER BLOCK INTERLOCK & TILE HOLLOW BRICKS

TEST RESULTS					
Identification of the block	Area of the Block (mms)	Maximum load taken (KN)	Compress ive strength	Correction Factor	Corrected Compressive strength (N/mm2)
1	30669	1350	44.02	1.18	51.94
2	30669	1340	43.69	1.18	51.55
3	30669	1480	48.26	1.18	56.95

Test conducted by:

Verified by:

Signature:

Signature:

COUNTER SIGNED AND ISSUED



Atun Jacon

Regional Engineer



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17120 Date: 08.09.2023

Ref:- Your request letter dtd:05.09.2023.

Testing of: 3 no's of concrete cube supplied for testing compresive strength. Project: Motel Aaram, Nedumangad.

Amount:1416/- Invoice No. 4076 Invoice Date: 05.09.2023

To The Regional Engineer State Nirmithi Kendra, Vattiyoorkavu.

Kerala Regional Office,

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₅	22.08.2023	760	33.78
2	M ₂₅	22.08.2023	780	34.67
3	M ₂₅	22.08.2023	640	28.44

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Have Classon

Regional Engineer



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17121 Date: 08.09.2023

Ref:- Your request letter dtd:07.09.2023.

Testing of: 3 no's of concrete cube supplied for testing compresive strength.

	Project: Cordial Paradise Poojapura.					
Date of testing:07.09.2023						
	Amount:1416/- Invoice No. 4087		Invoice Date: 07.09.2023			

To Cordial Homes Private Limited

TEST RESULTS				
Identification of the cube	Mix Date of casting		Maximum load taken (KN)	Compressive strength (N/mm2)
3F II Part	M ₂₅	30.07.2023	870	38.67
3F II Part	M ₂₅	30.07.2023	870	38.67
3F II Part	M ₂₅	30.07.2023	1060	47.11

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Han Carenul

Regional Engineer