



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17099

Date: 01.09.2023

Ref:- Your request letter 09.08.2023

Testing of: Square tubes supplied for taking unit weight.

Project: Broiler Breeding Farm, Kepco, Kudappanakunnu.

Amount:89/-	Invoice No. 3939	Invoice Date: 09.08.2023
-------------	------------------	--------------------------

To The Regional Engineer
Regional Office, Vattiyookavu.

TEST RESULTS		
Identification	Size of the section	Unit weight(Kg/m)
I	61mm X 40mm	3.48
II	40mm X 40mm	3.33
III	25mm X 25mm	1.75

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17100

Date: 01.09.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:

I-KL-KJML-ENB-0745, Vettamukku .

Amount:1416/-	Invoice No. 4080	Invoice Date: 01.09.2023
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrasrtructures (P)Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
TVDM 0745	M ₂₀	21.08.2023	500	22.22
TVDM 0745	M ₂₀	25.07.2023	460	20.44
TVDM 0745	M ₂₀	25.07.2023	560	24.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17101

Date: 01.09.2023

Ref:- Your request letter No.QA/SFS/008/67 dtd.01.09.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.
SFS AMBER Blue Block.

Project:

Amount:1416/-

Invoice No. 4059

Invoice Date: 01.09.2023

To M/s Skyline foundation and Srtuctures (P)Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
I	M ₃₀	22.08.2023	510	22.67
II	M ₃₀	22.08.2023	540	24.00
III	M ₃₀	22.08.2023	530	23.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17102

Date: 01.09.2023

Ref:- Your request letter No.QA/SFS/008/66 dtd.01.09.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.
SFS AMBER Blue Block (8th floor column).

Project:

Amount:1416/-

Invoice No. 4059

Invoice Date: 01.09.2023

To M/s Skyline foundation and Srtuctures (P)Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
I	M ₄₅	24.08.2023	820	36.44
II	M ₄₅	24.08.2023	910	40.44
III	M ₄₅	24.08.2023	810	36.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer