

KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

REGIONAL OFFICE
KODUMBU, PALAKKAD
PHONE No. 04912571492

No. Tech/108/13/RNK.P

Date: 08-09-2023

Ref:- 3nos of concrete cubes supplied for testing compressive strength on 28th day-main slab

Testing of: Additional works including lift in connection with construction of new labour room and OT as per laqshya stands at GSTH kottathara palakkad


CASH REMITTANCE DETAILS	
Amount ₹	1416.00
	Invoice No. 2436


To M/S Medigas system,59 RPC layout,8E cross road,attiguppe,vijayanagar
bangalore -560040.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
M20	M20	11-08-2023	450	20.00
"	"	"	460	20.44
"	"	"	480	21.33

Test conducted by: Jyothish.ks

Verified by: Santhandasan

Signature: 

Signature: 

COUNTER SIGNED AND ISSUED



Office Seal

GIRISHI. M.
Regional Engineer
Kerala State Nirmithi Kendra
Regional Centre, Palakkad