

KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17336

Date: 15.11.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd.15.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project:Cordial Deepam

Amount:1416/-	Invoice No. 4338	Invoice Date: 15.11.2023

To M/s Cordial Homes Private Limited.

Cordial Deepam.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M_{25}	05.10.2023	580	25.78
2	M_{25}	05.10.2023	620	27.56
3	M ₂₅	05.10.2023	580	25.78

COUNTER SIGNED AND ISSUED

Test conducted by:

Verified by:

Signature:

Signature:

THE THE PARAMETER STORY OF THE PARAMETER STOR

Regional Engineer

Office Seal



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:17338

Date: 15.11.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd.15.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project:Cordial Deepam

Amount:1416/-	Invoice No. 4339	Invoice Date: 15.11.2023		

To M/s Cordial Homes Private Limited.

Cordial Deepam.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M_{25}	20.10.2023	500	22.22
2	M_{25}	20.10.2023	580	25.78
3	M_{25}	20.10.2023	550	24.44

Test conducted by:

Verified by:

Signature:

Signature:

COUNTER SIGNED AND ISSUED

THE THE PARTY OF T

Office Seal Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:17339

Date: 15.11.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd.15.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Amount:1416/-	Invoice No. 4340	Invoice Date: 15.11.2023

To M/s Cordial Homes Private Limited. Cordial Paradise.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M_{25}	17.10.2023	670	29.78
2	M_{25}	17.10.2023	690	30.67
3	M_{25}	17.10.2023	750	33.33

COUNTER SIGNED AND ISSUED

Test conducted by: Verified by: Signature:

Signature:

Office Seal

Regional Engineer