

NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No.17249

Date: 17.10.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter no70/AE/LSGD/PKML/2023 dtd.16.10.2023 Testing of:3 no's of concrete cube supplied for testing compressive strenght. Project: Irappil Kottakkal road concreting in Pazhayakunnummel GP.

Amount: 1416/- Invoice No. 4238 Invoice Date: 17.10.2023

To The Assistant Engineer

LID

& EW Section, Pazhayakunnumel GP.

| TEST RESULTS | | | | |
|----------------------------|-----------------|-----------------|----------------------------|------------------------------|
| Identification of the cube | Mix | Date of casting | Maximum load taken (KN) | Compressive strength (N/mm2) |
| 1 | M_{20} | 10.10.2023 | 420 | 18.67 |
| 2 | M_{20} | 10.10.2023 | 420 | 18.67 |
| 3 | M ₂₀ | 10.10.2023 | 400 | 17.78 |

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

THE WALLANTHA PURMS

Office Seal

Regional Engineer

How James



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No.17250

Date: 17.10.2023

The Caronel

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd.17.10.2023

Testing of:3 no's of concrete cube supplied for testing compressive strenght.

Project: Artech PANORAMA Concrete supplier: Ultratech RMC.

| Amount:1416/- | Invoice No. 4240 | Invoice Date: 17.10.2023 |
|---------------|------------------|---------------------------------|

To The GM (Projects)

Artech Realtors (P) LTD.

| TEST RESULTS | | | | |
|----------------------------|----------|-----------------|----------------------------|------------------------------|
| Identification of the cube | Mix | Date of casting | Maximum load taken (KN) | Compressive strength (N/mm2) |
| 1 | M_{50} | 19.09.2023 | 1280 | 56.89 |
| 2 | M_{50} | 19.09.2023 | 1300 | 57.78 |
| 3 | M_{50} | 19.09.2023 | 1230 | 54.67 |

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

THE PARAMATHAPARA

Office Seal Regional Engineer



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No.17251

Date: 17.10.2023

Ham Jaming

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter no.KPHCC/PTA/MS/2023-24/07dtd.12.10.2023 Testing of:Coarse aggregate sample supplied for sieve anlysis (20mm metal).

Project: Construction of Mess Hall at Sannidhanam, Sabarimala.

Weight of sample 3000gms

Amount: 708/- Invoice No. 4216 Invoice Date: 13.10.2023

To The Project Engineer

Kerala Police Housing & Construction Corporation LTD.

| TEST RESULTS | | | | |
|-------------------------|--------------------------------|-----------------------------|-----------------------|-----------|
| IS Sieve Designation | Weight of sample retained (kg) | % weight of sample retained | Cumulative % retained | % passing |
| 40mm | 0.00 | 0.00 | 0.00 | 100.00 |
| 20mm | 2592.50 | 86.42 | 86.42 | 13.58 |
| 10mm | 407.50 | 13.58 | 100.00 | 0.00 |
| 4.75mm | 0.00 | 0.00 | 100.00 | 0.00 |
| Pan | 0.00 | 0.00 | 100.00 | 0.00 |

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

THE THE PARAMETERS OF THE PARA

Office Seal Regional Engineer



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No.17253

Date: 17.10.2023

Ithin Caring

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter no.KPHCC/PTA/MS/2023-24/07dtd.12.10.2023

Testing of: fine aggregate sample supplied for sieve anlysis.

Project: Construction of Mess Hall at Sannidhanam, Sabarimala.

Weight of sample 1500 gms

Amount: 708/- Invoice No. 4216 Invoice Date: 13.10.2023

To The Project Engineer

 $\label{lem:construction} \textbf{Kerala Police Housing \& Construction Corporation \ LTD.}$

Pathanamthitta.

| TEST RESULTS | | | | |
|-------------------------|---------------------------------|-----------------------------|-----------------------|-----------|
| IS Sieve Designation | Weight of sample retained (gms) | % weight of sample retained | Cumulative % retained | % passing |
| 4.75mm | 12.50 | 0.833 | 0.833 | 99.167 |
| 2.36mm | 259.50 | 17.300 | 18.133 | 81.867 |
| 1.18mm | 593.50 | 39.567 | 57.700 | 42.300 |
| 600 microns | 212.00 | 14.133 | 71.833 | 28.167 |
| 300 microns | 176.50 | 11.767 | 83.600 | 16.400 |
| 150 microns | 161.00 | 10.733 | 94.333 | 5.667 |
| 75 microns | 55.00 | 3.667 | 98.000 | 2.000 |
| Pan | 30.00 | 2.000 | 100.000 | 0.000 |

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

TARCAMANTHAS MAN TO STATE OF THE STATE OF TH

Office Seal Regional Engineer