

KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17293 Date: 31.10.2023

Ref:- Your request letter dtd.31.10.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Amount:1416/-	Invoice No. 4285	Invoice Date: 31.10.2023		

To M/s Cordial Homes Private Limited .

TEST RESULTS					
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)	
1	M ₂₅	28.09.2023	650	28.89	
2	M ₂₅	28.09.2023	820	36.44	
3	M ₂₅	28.09.2023	640	28.44	

Test conducted by: Verified by:

L

Signature: Signature:

COUNTER SIGNED AND ISSUED



Hann Caronal

Regional Engineer

Office Seal