

NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17354 Date: 22.11.2023

Ref:- Your request letter No.AEBL/SNORJBN/61/2022-ABL-PWD dtd.21.11.2023. Testing of: 3 no's of concrete cube supplied for testing compressive strenght. Project:Kerala Raj Bhavan-Re-Construction of collapsed retaining wall cum compound wall near Garage (Jawahar Nagar Side) of Raj Bhavan Campus.

Amount:2832/-	Invoice No. 4363	Invoice Date: 22.11.2023

To The Assistant Engineer

Raj Bhavan, Thiruvananthapuram.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₅	25.10.2023	590	26.22
2	M ₂₅	25.10.2023	580	25.78
3	M ₂₅	25.10.2023	580	25.78
4	M ₂₅	25.10.2023	580	25.78
5	M ₂₅	25.10.2023	580	25.78
6	M ₂₅	25.10.2023	570	25.33

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Han Jacom

Regional Engineer

Office Seal

Kerala



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17355 Date: 22.11.2023

Ref:- Your request letter no.878/SIPK-TVM-GH II/2023 dtd.22.11.2023 Testing of: 6 no's of concrete cube supplied for testing compressive strenght. Project:DR.GOVINDAN'S HOSPITAL-PHASE II, VANCHIYOOR. Code: 3rd floor column.

Amount:1416/-	Invoice No. 4364	Invoice Date: 22.11.2023

To M/s SI Property (Kerala) Private Limited .

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₅	15.11.2023	580	25.78
2	M ₂₅	15.11.2023	600	26.67
3	M ₂₅	15.11.2023	520	23.11

Test conducted by: Verified by:

Signature: Signature:

COUNTER SIGNED AND ISSUED

The Caronel

Regional Engineer



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17356 Date: 22.11.2023

Ref:- Your request letter no.BSC/103696/2021 dtd.14.11.2023

Testing of: 6 no's of concrete cube supplied for testing compressive strenght. Project:Construction of School building of Govt:Model Higher Secondary School, Varkala -Roof beam and Roof slab left phase.

Amount:2832/-	Invoice No. 4365	Invoice Date: 22.11.2023

To The Assistant Engineer Building Section, Chirayinkeezhu.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₃₀	20.10.2023	900	40.00
2	M ₃₀	20.10.2023	730	32.44
3	M ₃₀	20.10.2023	860	38.22
4	M ₃₀	20.10.2023	800	35.56
5	M ₃₀	20.10.2023	920	40.89
6	M ₃₀	20.10.2023	820	36.44

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Allen Caronal

Regional Engineer

Office Seal

PWD,



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17357 Date: 22.11.2023

Ref:- Your request letter 22.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Amount:1416/-	Invoice No. 4366	Invoice Date: 22.11.2023

To M/s Cordial Homes Private Limited. Cordial Deepam.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
10.10.2023	M ₂₅	10.10.2023	630	28.00
10.10.2023	M ₂₅	10.10.2023	640	28.44
10.10.2023	M ₂₅	10.10.2023	600	26.67

Test conducted by: Verified by:

Signature: Signature:

COUNTER SIGNED AND ISSUED



Ithur Claronel

Office Seal

Regional Engineer



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17358 Date: 22.11.2023

Ref:- Your request letter 22.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Amount:1416/-	Invoice No. 4366	Invoice Date: 22.11.2023

To M/s Cordial Homes Private Limited. Cordial Deepam.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
20.10.2023 M25	M ₂₅	20.10.2023	580	25.78
20.10.2023 M25	M ₂₅	20.10.2023	600	26.67
20.10.2023 M25	M ₂₅	20.10.2023	600	26.67

Test conducted by: Verified by:

Signature: Signature:

COUNTER SIGNED AND ISSUED



Hann Janan

Regional Engineer



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM		NO:17359 Date: 22.11.2023
Testing of: Cement s	ample supplied for various t Karakulam School building	
Amount:3186/-	Invoice No. 4292	Invoice Date: 01.11.2023
To The Assistant Engineer Section, Karakulam Grama Panchayath.		LSGD
	TEST RES	SULTS
1. % of water for sta	ndard consistency	= 34 %
2. Initial setting time		= 225 minutes
3. Final setting time		= 485 minutes
4. Fineness		= 1.17 %
5. Soundness		= 1mm(<10mm) sound
6. 7 th day compressiv	e strength	= 34.40 n/mm2

Test conducted by: Verified by:

Signature: Signature:

COUNTER SIGNED AND ISSUED



Hann Carenul

Regional Engineer



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17360 Date: 22.11.2023

Ref:- Your request letter 22.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Amount:1416/-	Invoice No. 4366	Invoice Date: 22.11.2023

To M/s Cordial Homes Private Limited.

Cordial Deepam.

TEST RESULTS						
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)		
9/11- M25	M ₂₅	09.11.2023	650	28.89		
9/11- M25	M ₂₅	09.11.2023	530	23.56		
9/11- M25	M ₂₅	09.11.2023	630	28.00		

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Ham Charamp

Office Seal

Regional Engineer



NIRMITHI TESTING LABORATORY CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17361 Date: 22.11.2023

Ref:- Your request letter 22.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght. Project: Motel Aaram at Nedumangad.

Amount:1416/-	Invoice No. 4367	Invoice Date: 22.11.2023

To The Regional Engineer State Nirmithi Kendra, Office, Vattiyoorkavu.

Kerala Regional

TEST RESULTS						
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)		
1	M ₂₅	12.10.2023	770	34.22		
2	M ₂₅	12.10.2023	700	31.11		
3	M ₂₅	12.10.2023	710	31.56		

Test conducted by: Verified by: Signature: Signature:

COUNTER SIGNED AND ISSUED



Hann Clasen

Regional Engineer