

KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

> NO:17367 Date: 25.11.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter no.SCTL/PRJ/241/2019/IT-TSCCC/8223

dtd:23.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project: Casting of Pile foundation Kundamankadavu, Mangalatukadavu, Killippalam.

Amount: 1416/- Invoice No. 4377 Invoice Date: 25.11.2023

To The Manager - Contacts & Projects

Smartcity Thiruvananthapuram Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M_{20}	18.11.2023	440	19.56
2	M_{20}	18.11.2023	410	18.22
3	M_{20}	18.11.2023	430	19.11

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

THE THE PARTY OF T

Office Seal

Regional Engineer

Ham minf



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:17369

Date: 25.11.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter dtd:25.11.2023.

Testing of: 2 no's of concrete cube supplied for testing compressive strenght.

Amount:944/-	Invoice No. 4376	Invoice Date: 25.11.2023

To Sri.Abhijith S A

Anusree, Panangode, Venganoor. PO

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
I	M_{20}	26.10.2023	490	21.78
II	M_{20}	26.10.2023	480	21.33

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

Office Seal Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU THIRUVANANTHAPURAM-695013 PHONE No. 0471 - 2362229

NO:17370

Hom Classing

No. T5/922/2021-22/RNK-TVPM

Date: 25.11.2023

Ref:- Your request letter dtd:25.11.2023.

Testing of: 2 no's of concrete cube supplied for testing compressive strenght.

Amount:944/-	Invoice No. 4376	Invoice Date: 25.11.2023

To Sri.Abhijith S A

Anusree, Panangode, Venganoor. PO

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
I	M_{20}	27.10.2023	330	14.67
II	M_{20}	27.10.2023	370	16.44

Test conducted by: Signature: Verified by: Signature:

COUNTER SIGNED AND ISSUED

THE PARAMETER OF STREET

Office Seal Regional Engineer