



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17398

No. T5/922/2021-22/RNK-TVPM

Date: 06.12.2023

Ref:- Your request letter dtd.06.12.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Hotel lemon tree.

Amount:1416/-	Invoice No. 4415	Invoice Date: 06.12.2023
---------------	------------------	--------------------------

To The Project Manager
AR Vista Pvt Ltd.

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₄₀	28.11.2023	910	40.44
2	M ₄₀	28.11.2023	1050	46.67
3	M ₄₀	28.11.2023	900	40.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer