



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17539

No. T5/922/2021-22/RNK-TVPM

Date: 18.01.2024

Ref:- Your request letter dtd 18.01.2024.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4632	Invoice Date: 18.01.2024
---------------	------------------	--------------------------

To M/s Cordial Homes (P) LTD
Cordial Paradise.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	20.12.2023	580	25.78
2	M ₂₅	20.12.2023	560	24.80
3	M ₂₅	20.12.2023	570	25.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17540

Date: 18.01.2024

Ref:- Your request letter no.SCTL/PRJ/210/2019/PMM/8420 dtd 03.12.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Smart City Roads - Road ID 27 (Utility duct side wall concreting).

Amount:1416/-

Invoice No. 4624

Invoice Date: 17.01.2024

To The Manager - Contracts & Projects
City Thiruvananthapuram Limited (SCTL).

Smart

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₂₅	13.12.2023	610	27.11
II	M ₂₅	13.12.2023	700	31.11
III	M ₂₅	13.12.2023	800	35.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17541

No. T5/922/2021-22/RNK-TVPM

Date: 18.01.2024

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Njaraneeli Kavuvila Bridge.

Amount:1416/-	Invoice No. 4634	Invoice Date: 18.01.2024
---------------	------------------	--------------------------

To The Assistant Engineer
Peringamala GP.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	1/1.5/3	04.01.2024	410	18.22
II	1/1.5/3	04.01.2024	540	24.00
III	1/1.5/3	04.01.2024	400	17.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17542

Date: 18.01.2024

Ref:- Your request letter dtd.17.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Asset Soveign, Oottukuzhy Jn., Statue - Member - Column .

Amount:1416/-

Invoice No. 4631

Invoice Date: 18.01.2024

To The Project Manager

GS

Builders and Contractors (P) Ltd.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₂₅	20.12.2023	1010	44.89
II	M ₂₅	20.12.2023	900	40.00
III	M ₂₅	20.12.2023	900	40.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17543

No. T5/922/2021-22/RNK-TVPM

Date: 18.01.2024

Ref:- Your request letter dtd.18.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: I-KL-CYKZ-ENB-9156, Kutumpuram.

Amount:1416/-	Invoice No. 4633	Invoice Date: 18.01.2024
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrastructure (P) LTD.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
CYKZ 9156	M ₂₀	20.12.2023	480	21.33
CYKZ 9156	M ₂₀	20.12.2023	780	34.67
CYKZ 9156	M ₂₀	20.12.2023	550	24.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17544

No. T5/922/2021-22/RNK-TVPM

Date: 18.01.2024

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: I-KL-CYKZ-ENB-9156, Kutumpuram.

Amount:1416/-	Invoice No. 4633	Invoice Date: 18.01.2024
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrastructure (P) LTD.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
CYKZ 9156	M ₂₀	18.12.2023	630	28.00
CYKZ 9156	M ₂₀	18.12.2023	590	26.22
CYKZ 9156	M ₂₀	18.12.2023	590	26.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer