



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17481

No. T5/922/2021-22/RNK-TVPM

Date: 03.01.2024

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:I-KL-KHYL-ENB-9001, Karode.

Amount:1416/-	Invoice No. 4566	Invoice Date: 03.01.2024
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrastrucure Pvt Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
KHYL-9001	M ₂₀	02.12.2023	450	20.00
KHYL-9001	M ₂₀	02.12.2023	490	21.78
KHYL-9001	M ₂₀	02.12.2023	450	20.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17482

No. T5/922/2021-22/RNK-TVPM

Date: 03.01.2024

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:I-KL-KHYL-ENB-9156, Kutumpuram.

Amount:1416/-	Invoice No. 4566	Invoice Date: 03.01.2024
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrastrucure Pvt Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
CYKZ - 9156	M ₂₀	24.12.2023	540	24.00
CYKZ - 9156	M ₂₀	24.12.2023	500	22.22
CYKZ - 9156	M ₂₀	24.12.2023	440	19.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17483

No. T5/922/2021-22/RNK-TVPM

Date: 03.01.2024

Ref:- Your request letter 01.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Pro.no.102/23, Renovation of Kannummoodu Kuttithanni road in ward 12.

Amount:472/-

Invoice No. 4568

Invoice Date: 03.01.2024

To The Assistant Engineer
LSGD Section,
Athyannoor Grama panchayath.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	26.12.2023	510	22.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17484

No. T5/922/2021-22/RNK-TVPM

Date: 03.01.2024

Ref:- Your request letter no. AB-202/AE/ATR/2023-24 dtd.01.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Pro.no.44/24 Completion of construction of drain in Adimalathura Beach road.

Amount:472/-

Invoice No. 4567

Invoice Date: 03.01.2024

To The Assistant Engineer
Athyannoor Block Panchayath.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	26.12.2023	430	19.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17485

No. T5/922/2021-22/RNK-TVPM

Date: 03.01.2024

Ref:- Your request letter no.AEXO/Nirmithi/cube/02.01.2024.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Construction of "Arcon Exotica" Near Kims.

Amount:1416/-	Invoice No. 4569	Invoice Date: 03.01.2024
---------------	------------------	--------------------------

To M/s Arcon Home Builders Private Limited.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
A1	M ₃₀	05.12.2023	890	39.56
A1	M ₃₀	05.12.2023	860	38.22
A1	M ₃₀	05.12.2023	810	36.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer